

# EU DECLARATION OF CONFORMITY

## No. 1A-EU-06/23-06

In accordance with EU directive 2014/35/EU as amended

We, **KOPOS KOLÍN a. s.**  
 Havlíčkova 432  
 280 02 Kolín  
 Czech Republic  
 IČ: 61672971  
 DIČ: CZ61672971

declare under our sole responsibility that

product **Elektroinstallation fire resistant boxes**


type: **KSK 80, KSK 100, KSK 125, KSK 175**  
 variants: **Orange**

manufacturer: **KOPOS KOLÍN a.s. Havlíčkova 432, Kolín IV, 280 02 Kolín, Czech Republic**

object of the declaration: **Boxes and covers used for electric accessories for house and other similar fixed electrical installations.**  
**Intended for installation in environments that require IP66 protection.**  
**Clow wire test satisfies: the membrane at 850 ° C, the lid of the box at 850 ° C and the Box body at 650 ° C.**  
**The needle burner test done**  
**Temperature resistance boxes during installation is from -25 ° C to + 60 ° C.**

The object of the declaration described above is in conformity with the relevant Union harmonisation legislation, other legislation and regulations:

Regulations Of the European Union	Government Regulations	Standards	Certificates and Test Reports	Other technical specification
2014/35/EU - LVD	Law No. 90/2016 Coll. as amended	ČSN EN IEC 60670-1 ed. 2:21+A11:21 cl. 14.1 and 14.3 including amendments	Test Report No. 230637-01/01 of 26.04.2023  Issued by: Electrotechnical Testing Institute, Pod Lisem 129, 171 02 Prague 71, Czech Republic	Test done: Rated insulation voltage 1000V
	Government Regulation No. 118/2016 Coll. as amended	ČSN EN IEC 60670-1 ed. 2:21 including amendments  ČSN EN 60670-1:05 including amendments (EN 60670-1:05 including amendments)  ČSN EN 60670-22:07 including amendments (EN 60670-22:06 including amendments)	Test Report No. 222525-01/01 of 28.11.2022 Test Report corrected on 06.01.2023  Issued by: Electrotechnical Testing Institute, Pod Lisem 129, 171 02 Prague 71, Czech Republic	X

		<p>ČSN EN 60670-1:05 including amendments (EN 60670-1:05 including amendments)</p> <p>ČSN EN 60670-22:07 including amendments (EN 60670-22:06 including amendments)</p>	<p>Test Report No. 702425-01/01 of 24.11.2017</p> <p>Issued by: Electrotechnical Testing Institute, Pod Lisem 129, 171 02 Prague 71, Czech Republic</p>	
		<p>ČSN EN 60670-1:05+A1:13 čl. 15.3 including amendments</p>	<p>Test Report No. 403994-01/01 of 26.11.2014</p> <p>Issued by: Electrotechnical Testing Institute, Pod Lisem 129, 171 02 Prague 71, Czech Republic</p>	<p>Impact test for boxes and enclosures:</p> <p>Cover KSK 100 Cover KSK 80</p>

By fulfilling the conditions in accordance with these regulations was placed on the product CE marking.  
Conformity assessment module: **MODUL A: Internal production control**

**Technical documentation of products:**

- assembly instructions
- Datasheet
- Catalog for products freely available on <http://www.kopos.com/en/catalogy>
- Internal documents

KOPOS KOLÍN a.s. company is certificated according to the standard ISO 9001:2015, ISO 14001:2015 and ISO 50001:2018 and according to the National program „Safety Enterprise“.

Signed on behalf of KOPOS KOLÍN a.s.




Place of issue: Kolín, Czech Republic

Ing. Jana Dejmková

Date of issue: 01.06.2023

quality director

KOPOS KOLÍN a.s.   
Havlíčková 432, 280 02 Kolín  
IČ: 616 72 971 DIČ: CZ61672971  
tel: 321 730 111 [www.kopos.cz](http://www.kopos.cz)