

# EU DECLARATION OF CONFORMITY

## No. 3B-EU-41/23-07

In accordance with EU directive 2014/35/EU as amended

We, **KOPOS KOLÍN a. s.**  
 Havlíčkova 432  
 280 02 Kolín  
 Czech Republic  
 IČ: 61672971  
 DIČ: CZ61672971

declare under our sole responsibility that

the product/type: **Cable protective conduit systems HDPE and accessories  
 06xxx (see Annex)**

manufacturer: **KOPOS KOLÍN a.s., Havlíčkova 432, Kolín IV, 280 02 Kolín, Czech Republic**

object of the declaration: Cable protective conduit systems designed to protect optical cables.  
 Material: HDPE  
 Shock resistance: normal (ČSN EN 61386-24)  
 Resistance to compression: 750 N  
 Bend resistance: flexible  
 The protectors are tested under pressure of 1,5 MPa for the time of 1 hour

The object of the declaration described above is in conformity with the relevant Union harmonisation legislation, other legislation and regulations:

Regulations Of the European Union	Government Regulations	Standards	Certificates and Test Reports	Other technical specification
2014/35/EU - LVD	Law No. 90/2016 Coll. as amended  Government Regulation No. 118/2016 Coll. as amended	ČSN EN 61386-1 ed. 2:09 including amendments (EN 61386-1:08 including amendments) ČSN EN 61386-24:11 including amendments (EN 61386-24:10 including amendments)	Test Report No. 701671-01/01 of 4.1.2018  Issued by: Electrotechnical Testing Institute, Pod Lisem 129, 171 02 Prague 71, Czech Republic	Designed for HDPE - type 40mm
2014/35/EU - LVD	Law No. 90/2016 Coll. as amended  Government Regulation No. 118/2016 Coll. as amended	ČSN EN 61386-1 ed. 2:09 including amendments (EN 61386-1:08 including amendments) ČSN EN 61386-24:11 including amendments (EN 61386-24:10 including amendments) ČSN EN ISO 9969:16	Test Report No. 704618-01/01 of 13.2.2018  Issued by: Electrotechnical Testing Institute, Pod Lisem 129, 171 02 Prague 71, Czech Republic	X
2014/35/EU - LVD	Law No. 90/2016 Coll. as amended  Government Regulation No.	ČSN EN 61386-1 ed. 2:09 including amendments (EN 61386-1:08 including amendments)	Test Report No. 205128-01/01 of 14.11.2012  Issued by:	X

	118/2016 Coll. as amended	ČSN EN 61386-24:11 including amendments (EN 61386-24:10 including amendments)	Electrotechnical Testing Institute, Pod Lisem 129, 171 02 Prague 71, Czech Republic	
2014/35/EU - LVD	Law No. 90/2016 Coll. as amended  Government Regulation No. 118/2016 Coll. as amended	ČSN EN ISO 9969:09 including amendments (EN ISO 9969:07 including amendments)  ČSN EN 61386-1 ed. 2:09 including amendments (EN 61386-1:08 including amendments)	Test Report No. 104108-01/01 of 29.11.2011  Issued by: Electrotechnical Testing Institute, Pod Lisem 129, 171 02 Prague 71, Czech Republic	06040, 06032
		ČSN EN ISO 1167-1, ČSN EN ISO 1167-2	Test Report No. P-VZLUTEST-298/20 of dne 24.9.2020  Issued by: VZLU TEST, a.s. Beranových 130, 199 00 Prague 9 - Letňany	Pressure test of single-skinned HDPE protectors, type: 40mm (BB58-30)
		ČSN EN ISO 1167-1, ČSN EN ISO 1167-2	Test Report No. P-VZLUTEST-497/17 of dne 18.12.2017  Issued by: VZLU TEST, a.s. Beranových 130, 199 00 Prague 9 - Letňany	Pressure test of single-skinned HDPE protectors, type: 40mm
		ČSN EN ISO 1167-1, ČSN EN ISO 1167-2	Test Report No. P-VZLUTEST-149/17 of dne 18.4.2017  Issued by: VZLU TEST, a.s. Beranových 130, 199 00 Prague 9 - Letňany	Pressure test of single-layer HDPE protectors, type: 40mm diameter (Liten, Granic)
		ČSN EN ISO 9969	Materials for projection of plastic cable protectors KOPOS 2018  Issued by: EGÚ Brno, a.s. Electrical networks division Hudcova 487/76a 612 48 Brno-Medlánky	Circular stiffness  Type: Cable protective 06040
		ČSN EN ISO 9969	Materials for projection of plastic cable protectors KOPOS 2015  Issued by: EGÚ Brno, a.s. Electrical networks division Hudcova 487/76a	Circular stiffness  Type: Cable protective 06025

		<b>ČSN EN ISO 9969</b>	612 48 Brno-Medlánky Materials for projection of plastic cable protectors KOPOS 2013  <b>Issued by:</b> EGÚ Brno, a.s. Electrical networks division Hudcova 487/76a 612 48 Brno-Medlánky	<b>Circular stiffness</b>  <b>Type: Cable protective 06050</b>  <b>Type: HDPE 06050</b>
		<b>ČSN EN ISO 9969</b>	Materials for projection of plastic cable protectors KOPOS 2012  <b>Issued by:</b> EGÚ Brno, a.s. Electrical networks division Hudcova 487/76a 612 48 Brno-Medlánky	<b>Circular stiffness</b>  <b>Type: Cable protective 06032, 06040</b>
<b>1907/2006 - REACH</b>				<b>MSDS for used materials</b>

By fulfilling the conditions in accordance with these regulations was placed on the product CE marking.

Conformity assessment module: **MODUL A: Internal production control**

**Technical documentation of products:**

- assembly instructions
- Datasheet
- Catalog for products freely available on <http://www.kopos.com/en/catalogy>
- Internal documents

KOPOS KOLÍN a.s. company is certificated according to the standard ISO 9001:2015, ISO 14001:2015, ISO 50001:2018 and according to the National program „Safety Enterprise“.

Signed on behalf of KOPOS KOLÍN a.s.


Place of issue: Kolín, Czech Republic

Date of issue: 19.07.2023



**Ing. Jana Dejmková**

quality director

**KOPOS KOLÍN a.s.**   
 Havlíčkova 432, 280 02 Kolín  
 IČ: 616 72 971 DIČ: CZ61672971  
 tel: 321 730 111 [www.kopos.cz](http://www.kopos.cz)

**Enclosure No. 1 to EU Conformity Declaration No. 3B-EU-41/23-07**  
**Cable protective conduit systems HDPE and accessories**

<b>Cable protective conduit systems HDPE</b>	<b>Couplings</b>	<b>Endings</b>
06016	05016	05015, 05017
06020	05020	05019, 05021
06025	05025	05024, 05026
06032	05030, 05033	05031, 05032
06040	05040, 05043	05041, 05042
06050	05050, 05053	05051, 05052
06063	05063	05062, 05064
06075	05075	05074, 05076