

EU DECLARATION OF CONFORMITY

No. 1A-EU-03/23-09

In accordance with EU directive 2014/35/EU as amended

We, **KOPOS KOLÍN a. s.**
 Havlíčkova 432
 280 02 Kolín
 Czech Republic
 IČ: 61672971
 DIČ: CZ61672971

declare under our sole responsibility that

the product/type: **Wiring boxes to hollow walls and accessories**

manufacturer: **KOPOS KOLÍN a.s., Havlíčkova 432, Kolín IV, 280 02 Kolín, Czech Republic**

object of the declaration: It serves as a conduit boxes into hollow walls eg. of drywall or wood paneling.
 Test with flaming loop: 850 ° C
 Needle burner test performed.
 Minimum and maximum temperatures during installation are -5 ° C to + 60 ° C.
 The IP 30 enclosures meet the enclosure fitted with the appropriate lid or device with a coverage equal to or higher than IP 30.

The object of the declaration described above is in conformity with the relevant Union harmonisation legislation, other legislation and regulations:

Regulations Of the European Union	Government Regulations	Standards	Certificates and Test Reports	Other technical specification/tested products
2014/35/EU - LVD	Law No. 90/2016 Coll. as amended Government Regulation No. 118/2016 Coll. as amended	ČSN EN IEC 60670-1 ed.2:21 including amendments ČSN EN 60670-22:07 including amendments (EN 60670-22:06 including amendments) ČSN EN 60695-11-5 ed. 2:17 including amendments (EN 60695-11-5:17 including amendments)	Test Report No. 231833-01/01 of 23.08.2023 Issued by: Elektrotechnický zkušební ústav, Pod Lisem 129, 171 02 Praha 71, Czech Republic	KPL 64-50/LD, KPL 64-50/LD HF
X	X	ČSN EN ISO 10140-2_2022	Report No. 040-073805 of 08.02.2023 on the test-Determination of Air sound insulation according to ČSN EN ISO 10140-2:2022 Issued by: Technical and Testing Institute of Construction	Double sheathed plasterboard partitions with the 2x CW/UW 75 double metal construction filled with mineral wool ΔR_w 69 dB. Tested products: KO 180/LD, KO 97/LD, KPL 64-50/5LD, KPRL 68-70/LD, KUL 68-45/LD

			PRAHA, s.p., Tolského 447, 415 03 Teplice, Czech Republic	
			Issued on the basis of protocol No. 040-073805 expert opinion 040-074030 of 10.03.2023 Issued by: Technical and Testing Institute of Construction PRAHA, s.p., Tolského 447, 415 03 Teplice, Czech Republic	Expert opinion of the effect of electrical junction boxes on the weighted laboratory sound reduction index R_w of plasterboard walls. <ol style="list-style-type: none"> In all laboratory verified configurations we have found that the improvement/impairment of the weighted laboratory sound reduction index was $\Delta R_w = 0$ dB. <ol style="list-style-type: none"> The measured results are also valid for boxes with a smaller surface area. The measured results are also valid for boxes with smaller depths. The results reported in 040-073805 reports are valid for all double sheathed plasterboard partitions with a double metal construction filled with mineral wool with the weighted laboratory sound reduction index $R_w \leq 69$ dB.
2014/35/EU - LVD	Law No. 90/2016 Coll. as amended Government Regulation No. 118/2016 Coll. as amended	ČSN EN IEC 60670-1 ed.2:21 including amendments ČSN EN 60670-1:05+Z1:10+A1:13+Z2:21 including amendments (EN 60670-1:05 including amendments) ČSN EN 60670-22:07 including amendments (EN 60670-22:06 including amendments) ČSN EN 60695-11-5 ed. 2:17 including amendments (EN 60695-11-5:17 including amendments)	Test Report No. 230017-01/01 of 31.01.2023 Issued by: Elektrotechnický zkušební ústav, Pod Lisem 129, 171 02 Praha 71, Czech Republic	Wiring boxes to hollow walls and accessories
2014/35/EU - LVD	Law No. 90/2016 Coll. as amended Government Regulation No. 118/2016 Coll. as	ČSN EN 60670-1:05+Z1:10+A1:13 including amendments (EN 60670-1:05 including amendments) ČSN EN 60670-22:07 including	Test Report No. 604795-01/01 of 8.12.2016 Issued by: Elektrotechnický	Double-phase injection boxes and accessories

	amended	amendments (EN 60670-22:06 including amendments)	zkušební ústav, Pod Lisem 129, 171 02 Praha 71, Czech Republic	
2014/35/EU - LVD	Law No. 90/2016 Coll. as amended Government Regulation No. 118/2016 Coll. as amended	ČSN EN 60670-1:05+Z1:10+A1:13 including amendments (EN 60670-1:05 including amendments) ČSN EN 60670-22:07 including amendments (EN 60670-22:06 including amendments)	Test Report No. 701046-01/01 of 4.4.2017 Issued by: Elektrotechnický zkušební ústav, Pod Lisem 129, 171 02 Praha 71, Czech Republic	Wiring boxes to hollow walls and accessories
2014/35/EU - LVD	Law No. 90/2016 Coll. as amended Government Regulation No. 118/2016 Coll. as amended	ČSN EN 60670-1:05 including amendments (EN 60670-1:05 including amendments) ČSN EN 60670-22:07 including amendments (EN 60670-22:06 including amendments)	Test Report No. 600815-01/01 of 19.10.2018 Issued by: Elektrotechnický zkušební ústav, Pod Lisem 129, 171 02 Praha 71, Czech Republic	Wiring boxes KU 68 LD
2014/35/EU - LVD	Law No. 90/2016 Coll. as amended Government Regulation No. 118/2016 Coll. as amended	ČSN EN 60670-1:05+Z1:10+A1:13 including amendments (EN 60670-1:05 including amendments) ČSN EN 60670-22:07 including amendments (EN 60670-22:06 including amendments) ČSN EN 60695-11-5 ed. 2:17 including amendments (EN 60695-11-5:17 including amendments)	Test Report No. 020219-01/01 of 26.2.2020 Issued by: Elektrotechnický zkušební ústav, Pod Lisem 129, 171 02 Praha 71, Czech Republic	Wiring boxes KO 180/LD
			Internal protocol of enclosure IP wiring boxes to hollow walls (listed in the Annex below)	Compliant tests for IP30: Applies to wiring boxes PVC and HF
			internal protocols	
				Halogen-free (HF) according to documents from the supplier
				Safety data sheets for used materials
Regulation 1907/2006 - REACH				

By fulfilling the conditions in accordance with these regulations was placed on the product CE marking.

Conformity assessment module: **MODUL A: Internal production control**

Technical documentation of products:

- assembly instructions
- Datasheet
- Catalog for products freely available on <http://www.kopos.com/en/catalog>
- Internal documents

KOPOS KOLÍN a.s. company is certificated according to the standard ISO 9001:2015, ISO 14001:2015 and ISO 50001:2018 and according to the National program „Safety Enterprise“.

Signed on behalf of KOPOS KOLÍN a.s.


A handwritten signature in blue ink, appearing to read 'Jana Dejmková'.

Place of issue: Kolín, Czech Republic

Ing. Jana Dejmková

Date of issue: 13.09.2023

quality director

KOPOS KOLÍN a.s. 
Havlíčkova 432, 280 02 Kolín
IČ: 616 72 971 DIČ: CZ61672971
tel: 321 730 111 www.kopos.cz

Enclosure No. 1 to EU Conformity Declaration No. 1A-EU-03/23-09
Wiring boxes and accessories- in hollow walls

Boxes

Type

KU 68 LD	KU 68 LD HF
KU 68 LD/1	KU 68 LD/1 HF
KU 68 LD/2	KU 68 LD/2 HF
KU 68 LD/3	KU 68 LD/3 HF
KU 68/71 LD	KU 68/71 LD HF
KU 68/71 LD 1	KU 68/71 LD 1 HF
KU 68/71 LD 2	KU 68/71 LD 2 HF
KU 68/71 LD 3	KU 68/71 LD 3HF
KP 64/LD	KP 64/LD HF
KP 64/2LD	KP 64/2LD HF
KP 64/3LD	KP 64/3LD HF
KP 64/4LD	KP 64/4LD HF
KP 64/5LD	KP 64/5LD HF
KPR 68/LD	KPR 68/LD HF
KPR 68/71 LD	KPR 68/71 LD HF
KO 97/LD	KO 97/LD HF
KR 97/LD	KR 97/LD HF
KO 110/LD	KO 110/LD HF
KO 125/1LD	KO 125/1LD HF
KO 180/LD	KO 180/LD HF
KO 180-V/LD	KO 180-V/LD HF
KO 180-VO/LD	KO 180-VO/LD HF
KR 110/LD	KR 110/LD HF
KT 250/LD	KT 250/LD HF
KPM 64/LD	KPM 64/LD HF
KPM 64/LDU	KPM 64/LDU HF
KR 35 LD	KR 35 LD HF
KUH 1/LD	KUH 1/LD HF
KUH 1/LDU	KUH 1/LDU HF
KUL 68-45/LD	KUL 68-45/LD HF
KUL 68-45/LD1	KUL 68-45/LD1 HF
KUL 68-45/LD2	KUL 68-45/LD2 HF
KUL 68-45/LD3	KUL 68-45/LD3 HF
KUL 68-35/LD	KUL 68-35/LD HF
KPRL 64-60/LD	KPRL 64-60/LD HF
KPRL 68-70/LD	KPRL 68-70/LD HF
KPL 64-45/LD	KPL 64-45/LD HF
KPL 64-50/LD	KPL 64-50/LD HF
KPL 64-50/2LD	KPL 64-50/2LD HF
KPL 64-50/3LD	KPL 64-50/3LD HF
KPL 64-50/4LD	KPL 64-50/4LD HF

KPL 64-50/5LD
KOL 97/LDKPL 64-50/5LD HF
KOL 97/LD HF**Boxes****Type**

KU 68/71L1

KU 68/71L1 HF

KPR 68/L

KPR 68/L HF

KPR 68/71L

KPR 68/71L HF

KU 68 LA/1

KU 68 LA/1 HF

KU 68 LA/2

KU 68 LA/2 HF

KU 68 LA/3

KU 68 LA/3 HF

KU 68/71L - 1

KU 68/71L - 1 HF

KU 68/71L - 2

KU 68/71L - 2 HF

KU 68/71L - 3

KU 68/71L - 3 HF

KI 68 L/1

KI 68 L/1 HF

KI 68 L/2

KI 68 L/2 HF

KI 68 L/3

KI 68 L/3 HF

KP 64/LE

KP 64/LE HF

KP 64/LA

KP 64/LA HF

KP 64/2L

KP 64/2L HF

KP 64/3L

KP 64/3L HF

KP 64/4L

KP 64/4L HF

KP 64/5L

KP 64/5L HF

KO 97/L

KO 97/L HF

KR 97/L

KR 97/L HF

KO 110/L

KO 110/L HF

KR 110/L

KR 110/L HF

KO 125/1L

KO 125/1L HF

KT 250/L

KT 250/L HF

KPM 64/L

KPM 64/L HF

KPM 64/LU

KPM 64/LU HF

KOM 97/LU

KOM 97/LU HF

KR 35L

KR 35L HF

KUH 1/L

KUH 1/L HF

Accessories**Cover**

V 68

V 68 HF

V 180

VO 180

KO 68

KO 68 HF

KO 97 V

KO 97 V HF

KO 97 V/1

KO 97 V/1 HF

V 35

V 35 HF

V 125/1	V 125/1 HF
ZV 68	ZV 68 HF
ZV 97	ZV 97 HF
V 110/L	V 110/L HF
VKT 250/L	VKT 250/L HF
VKP 64/2L	VKP 64/2L HF
VKP 64/3L	VKP 64/3L HF
VKP 64/4L	VKP 64/4L HF
VKP 64/5L	VKP 64/5L HF

Extension mandrelTN 68
TN 97**Clutch of KUL boxes**

SKLD 2

Mounting ring

MK 64	MK 64 HF
MKU 64	MKU 64 HF
MKU 97	MKU 97 HF

Bar


P 110L	P 110L HF
--------	-----------

TerminalS-66
S-96
SP-96

MP 3

MP 3-3CH
M3X45-3CH
M3X40-3CH**Foot, screw**3x20V-2CH
3x25V-2CH
3x35V-2CH
3x38

Foot CR

2,9X13V
2,9X13Z
2,9x22
30x16**KOPOS KOLÍN a.s.** 
Havlíčková 432, 280 02 Kolín
IČ: 616 72 971 DIČ: CZ61672971
tel: 321 730 111 www.kopos.cz

