

EU DECLARATION OF CONFORMITY

No. 1B-EU-13/24-03

In accordance with EU directive 2014/35/EU as amended

We, **KOPOS KOLÍN a. s.**
Havlíčková 432
280 02 Kolín
Czech Republic
IČ: 61672971
DIČ: CZ61672971

declare under our sole responsibility that

the product/type: **Floor boxes KOPOBOX (see Annex)**

manufacturer: **KOPOS KOLÍN a.s., Havlíčkova 432, Kolín IV, 280 02 Kolín, Czech Republic**

object of the declaration: KOPOBOX floor boxes are suitable for installation into concrete with a maximum temperature during the casting process of +60°C.
Temperature resistance: from -5 ° C to + 60 ° C.
The degree of protection box is: IP 30.
KOPOBOX meets the glow-wire test at: 850 ° C according to ČSN EN 60670-1 cl.18 and ČSN EN 60670-1 ed.2 cl.18.
The needle burner test was conducted in accordance with ČSN EN 60695-11-5 with satisfactory result.

The object of the declaration described above is in conformity with the relevant Union harmonisation legislation, other legislation and regulations:

Regulations Of the European Union	Government Regulations	Standards	Certificates and Test Reports	Other technical specification
2014/35/EU - LVD	Law No. 90/2016 Coll. as amended Government Regulation No. 118/2016 Coll. as amended	ČSN EN 60670-1:05 including amendments (EN 60670-1:05 including amendments) ČSN EN 60670-23:09 including amendments (EN 60670-23:08 including amendments) ČSN EN IEC 60670-1 ed. 2:21 including amendments ČSN 33 2312 ed.2:14 čl.4.5 including amendments	Test Report No. 221569-01/01 of 26.08.2022 Issued by: Electrotechnical Testing Institute, Pod Lisem 129, 171 02 Prague 71, Czech Republic	
2014/35/EU - LVD	Law No. 90/2016 Coll. as amended Government Regulation No. 118/2016 Coll. as amended	ČSN EN 60670-1:05 including amendments (EN 60670-1:05 including amendments) ČSN EN 60670-23:09 including amendments (EN 60670-23:08 including amendments) ČSN 33 2312 ed.2:14 čl.4.5 including amendments	Test Report No. 910899-01/01 of 31.5.2019 Issued by: Electrotechnical Testing Institute, Pod Lisem 129, 171 02 Prague 71, Czech Republic	
		ČSN EN 60670-1:05 including amendments (EN 60670-1:05 including amendments) ČSN EN IEC 60670-1 ed. 2:21 including amendments	Internal protocol no.036/2024 of 04.03.2024	KM 45

Regulation 1907/2006 - REACH				Safety data sheets for used materials
------------------------------------	--	--	--	--

By fulfilling the conditions in accordance with these regulations was placed on the product CE marking.

Conformity assessment module: **MODUL A: Internal production control**

Technical documentation of products:

- assembly instructions
- Datasheet
- Catalog for products freely available on <http://www.kopos.com/en/catalogy>
- Internal documents


KOPOS KOLÍN a.s. company is certificated according to the standard ISO 9001:2015, ISO 14001:2015 and ISO 50001:2018 and according to the National program „Safety Enterprise“.

Signed on behalf of KOPOS KOLÍN a.s.



Place of issue: Kolín, Czech Republic
Date of issue: 05.03.2024

Ing. Jana Dejmková
Quality and Ecology Director

KOPOS KOLÍN a.s. 
Havlíčková 432, 280 02 Kolín
IČ: 616 72 971 DIČ: CZ61672971
tel: 321 730 111 www.kopos.cz

Enclosure No. 1 to EU Conformity Declaration No. 1B-EU-13/24-03**Floor boxes KOPOBOX and accessories****Frame of the floor box:**KOPOBOX 57
KOPOBOX 80**Floor box:**KUP 57
KUP 80
KUP 80/12**Instrument floor box:**

KPP 80

Instrument floor box lateral:

KPP 80/142

Universal metal box:

KUK 80

Instrument washer:

PP 80/0	PP 80/142-0	PP 80/K-1
PP 80/3	PP 80/142-1	PP 80/K-2
PP 80/45	PP 80/142-2	PP 80/K-3
	PP 80/142-3	PP 80/K-4
	PP 80/142-45	

PP 80/45/6_LB

Blind cover:

ZPP

Cover of modul 45

KM 45

Partition:PKUP
PKUP 142**Set of leveling:**

SN

Partition:PKUP
PMPP 80/45/6
PMPP 80/45/12**KOPOS KOLÍN a.s.** 
Havlíčková 432, 280 02 Kolín
IČ: 616 72 971 DIČ: CZ61672971
tel: 321 730 111 www.kopos.cz

